


1. CONNECTION TO MAIN LINE AND FIRST AUXILIARY VALVE SHALL BE FLANGED.
2. FOR HYDRANT LATERAL LENGTHS OVER 6 L.F. INSTALL AN ADDITIONAL 6" FLG X MJ GATE VALVE AT THE HYDRANT
3. PIPE BEDDING SHALL COMPLY WITH SANDY CITY STANDARDS SPECIFICATIONS
4. ALL BOLTS, NUTS, AND T-BOLTS SHALL BE LUBRICATED WITH FML GREASE.
5. USE ROMAC GRIP RING FOR PVC PIPE & MEGALUGS FOR DIP.



1	CC	CREATED	6/2017		STANDARD DETAIL PUBLIC UTILITIES
NO.	AUTHORIZED BY	REVISIONS	DATE		WTR-01 FIRE HYDRANT CONNECTION